



Per code requirements please leave 3" on each side of the cabinet including the back, and a 3 foot clearance in front.

\*Contact factory for further options.

\*Contact factory for special conduit access arrangements

Notice: This drawing contains confidential and proprietary data originated. All design, manufacturing, reproduction, use and sale rights are expressly reserved. The recipient agrees by accepting this document, not to supply or disclose and information regarding it to any unauthorized person, or to incorporate this data into any other design or use thereof. All patent rights are expressly reserved.

NEMA 3R  
Conduit Dimensions

Drawing #  
070-0014-01

Drawing by: H.A. Berger

**DSPM** INC.  
DIGITAL SIGNAL POWER MANUFACTURER  
www.DSPManufacturing.com

439 S. Stoddard Avenue  
San Bernardino, CA 92401  
Ph: 1.877.DSPM POWER  
1.877.377.6769  
Fax: 909.930.3335  
E-Mail: engineering@dspmanufacturing.com

Revision  
Level  
NR

Sheet 1 of 1